

**EASTSOUND SEWER AND WATER DISTRICT
WASTEWATER TREATMENT PLANT UPGRADE – PHASE 2**

**ADDENDUM NO. 5 (1 page total)
Issue Date: March 17, 2025**



03-17-2025

General: Recitations of each and every section of the bid documents impacted by this addendum are not given. The described changes impact all relevant portions of the bid documents whether specifically cited below or not.

CONTRACT CLARIFICATIONS:

1. General Contractor Questions:

Q: I didn't see in the information on Train #1 & #2 where there was a steel thickness called out. Do you happen to know that?

A: The existing wall (steel plate), measured at the top, is approximately ¼ inch thick.

***** END OF ADDENDUM *****